

VENUE: XXXXXXXXX

PRODUCTION: XXXXXXXXX

TIME/DAY/DATE: 4pm, Friday, 01/04/2008

CLAMP METER READINGS TAKEN DURING REHEARSAL
(All readings in Amperes)

Lighting Service #1	Grn	Wht	Blk	Red	Blu
Fluke 30	1	9	198	227	195
Fluke 336	1.3	15.2	202.2	230.1	199.3

Lighting Service #2	Grn	Wht	Blk	Red	Blu
Fluke 30	2	2	302	304	263
Fluke 336	1.1	0.7	299.1	307.3	265.2

Lighting Service #3	Grn	Wht	Blk	Red	Blu
Fluke 30	2	6	34	33	26
Fluke 336	2.6	8.1	35.2	35.3	27.1